

March 7, 2024

TO: Contractors & Suppliers

SUBJECT: Lostat  
Proposed Village Hall  
**ADDENDUM NO. 1**

---

This Addendum shall consist of the following items:

1. Light Fixture Type for Rooms 107 and 113.
  - a. Room 107 – Fixture Type “D” (See Electrical Legend)
  - b. Room 113 - Fixture Type "B" (See Electrical Legend)
2. Light Fixture in Rooms 101, 109 and 110 shall be fixture Type “G” and not Type “H” as indicated on Electrical Plan.
  - Note: Contractors may substitute Type “G” fixture specified on plans with A (6”) deep regressed wafer downlight with baffle, selectable lumens. CCT-90CR1. Matte white as manufactured by “Juno” #WF6D12EGBALZO.
3. If garage structure Alternate is not accepted, the Contractors shall provide Type “E” light fixture over Door #1. Also, Contractors shall provide a combo exit light with remote head at Door #1 if Alternate is not accepted.
4. Exterior wall mounted fixtures shall have the following Lumens
  - a. Type “E” – 1645 Lumens
  - b. Type “F” – 6850 Lumens
5. The ceiling fan specified is based on a “Hunter” Dempsey low profile with remote, 52” (white), no light kit, 3 speed motor. Depth (ceiling to blade) = 8.08”. Approved equal may be accepted.

This Addendum is also posted at our website: [www.chamlin.com](http://www.chamlin.com)

Please be advised that this Addendum must be acknowledged on the Bid Form. Failure to do so may result in rejection of your Bid.

Sincerely,  
CHAMLIN & ASSOCIATES, INC.



David A. Hall, P. E.

DAH:mrc

cc: File No.111518.00